

Certificate of Product Approval

Licensee:

Bahra Cables Company

CPC Industrial Park, Bahra, 21432, Jeddah, Saudi Arabia

Factory:

CPC Industrial Park, Bahra, 21432, Jeddah, Saudi Arabia

Standard:

IEC 60502-2:2014

Description:

Medium voltage power cables up to 33kV

Details:

XLPE Insulation. Bonded or strippable semi-conducting insulation screen. Copper tape and/or copper wire screened. Low smoke, zero halogen, extruded inner sheath. Galvanised steel round wire armoured (3-core cables). Aluminium round wire armoured (single-core cables).

ST8 low smoke, zero halogen, extruded outer sheath. Voltage ratings: 3.6/6(7.2kV), 6/10(12)kV and 8.7/15(17.5)kV. Generally to IEC 60502-2 and including IEC 60332-3.24, IEC 61034 and IEC 60754 specifications.

Materials:

Insulation XLPE, Sheath ST 8

Brand Name:

N/A

Origin Mark:

BAHRA CABLES CO. or BAHRA CABLES

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri

Date: 31/10/2022

Date of original issue: 30/11/2011

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 4 (21-10-2021)



Expiry date:
12/06/2026



Certificate No:
178/001/048
Issue No: 5

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
N/A	N/A	Class 2	1	10	630
N/A	N/A	Class 2	3	10	400

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri Date: 31/10/2022

Date of original issue: 30/11/2011

Check BASEC website to verify validity.
Page 2 of 2



Expiry date:
12/06/2026