

## Certificate of Product Approval

Licensee:

### **Bahra Cables Company**

CPC Industrial Park, Bahra, 21432, Jeddah, Saudi Arabia

Factory:

CPC Industrial Park, Bahra, 21432, Jeddah, Saudi Arabia

Standard:

IEC 60502-2:2014

Description:

Medium voltage power cables up to 33kV

Details:

Bonded or strippable semi-conducting insulation screen. Copper tape and/or copper wire screened. Low smoke, zero halogen, extruded inner sheath. ST8 low smoke, zero halogen, extruded outer sheath. Aluminium/MDPE laminated sheathed / Lead sheathed. Water blocked and non-water blocked types. Voltage ratings: 3.6/6(7.2)kV, 6/10(12)kV, 8.7/15(17.5)kV, 12/20(24)kV and 18/30(36)kV.

Materials:

Insulation XLPE, Sheath ST 8

Brand Name:

N/A

Origin Mark:

BAHRA CABLES CO. or BAHRA CABLES

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the  
British Approvals Service for Cables

*Tony Lioveri*

Date: 31/10/2022

Date of original issue: 27/02/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No. 1150237, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 4 (21-10-2021)



Expiry date:  
**12/06/2026**



Certificate No:  
**178/001/057**  
Issue No: 2

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
N/A	N/A	Class 2	1	10	630

Signed for and on behalf of the  
British Approvals Service for Cables

*Tony Lioveri* Date: 31/10/2022

Date of original issue: 27/02/2012  
Check BASEC website to verify validity.  
Page 2 of 2



Expiry date:  
**12/06/2026**